ELSAFE INDIA

Leading The Way To Safey

Cochin - Chennai - Bangaluru - Hyderabad - UAE

ALL INDIA TOLL FREE NUMBER 1800-121-9092

www.elsafeindia.com, info@elsafeindia.com Ph No: 0484-2575199-210, Fax: 0484-2575211







QUOTATION

Project Name: TEK1000-VILLA

Quote #: 1712121Q

Company: Residential-Total Protection



These are Residential Packages for Houses at Kerala State only, ALL KERALA FREE DELIVERY, NO HIDDEN CHARGES, FIXED RATE

Revision: Terms: ***

Ship via: Land Cargo FOB: Ex-Factory Weight: *** As applicable

Number	Item	Description	Qty.	Unit	Unit Cost (in INR)		Total Cost (in INR)	
		Lightning Protection System						
1	LA TERMINAL	TeksoPrevent MODEL: TEK1000 (Lightning Arrestor) Supply of Lightning arrestor Tekso Prevent Air terminal which is a Copper built lightning arrestor. 1. Large protection region; High performance 2. High quaity 3. Strong anti-corrosion and conductivity	1	No	INR	22,150.00	INR	22,150.00
2	Earthing	Model: TEKSAI Copper rod 2 Nos Spec: 2 Mtr Length x 14.2 mm dia x250 micron (ISO 9001-2008 Certified Company), CPRI Approved, Maintance free Earthing. Model: TEKSAI ELECTRON - High Conductive Concrete (High Conductive & Anti Corrosive Compound) Application: Superior Choice & Reliable Performance for all Soil / Sandy / Rocky / Filled sand location ELECTRON 4 bags	1	set	INR	7,000.00	INR	7,000.00
3	Down conductor	HRFR V.GUARD COPPER CABLES 50 SQ MM	20	Mtrs	INR	550.00	INR	11,000.00
4	Elevation Mast	Specially designed 3mtr GI mast, 1Feet FRP Mast with LA Base, adaptor, Ancoring rope if required and Accessories	1	set	INR	5,750.00	INR	5,750.00
5	Installation	Installation	1	Nos	INR	4,000.00	INR	4,000.00
6	Surge Protector Device	Imported 3 Phase/1 Phase Class B SPD, Phoenix/LSG	1	No	Co	omplementory	С	omplementory
Quotation Valid For 20 days GRAND TOTAL			INR	49,900.00				

Terms & Conditions

- 1 Price Landed at site
- 2 Customers Scope: Material safety will be customer scope after delivery
- Approvals /Permission of work/storage of tools & equipment/safety etc : At customers scope 3

Thank you,

Best Regards


ELSAFE PROTECTION & CONTROL SYSTEMS


Ph No 0484-2575199, Toll free 1800-121-9092

Doc. No.: ES19200407

Rev. No.:

Rev. Date :





PROTECTION LEVEL	EFFECTIVENESS OF LIGHTNING CONDUCTOR E
1/ //	0.98
II	0.95
111	0.90
IV	0.80



Particulars	Specification
Material	Copper
Air Rod Height	300 MM
Air Rod Diameter	100 MM
Protection Angle	65°
Corresponding Protection Radius	2.14 h
Max Impulse Current Discharge	50 KA
Average Discharge Current	25 KA
Current Gradient Less Than	40KA
Grounding Resistance	Less Than 10 Ohm
Resistible Wind Speed	Over 50m/s















www.teksaiearthing.com

Marketing office kerala

ELSAFE PROTECTION AND CONTROL SYSTEMS D10-4/60, Densons Building Marottichodu, Edapally, Cochin, Kerala Ph No: 0484 - 2575199 info@elsafeindia.com www.elsafeindia.com

Distributor / Dealer

Blue Star Industries

Kanjikode West Palakkad-678623 Kerala, India Ph no: 0491-2803511-521



Certificate of Quality

Test Details

	: 16021025	Volume resistivity, IEC60093	: 1E13/1E9 Ω*m
Serial Number	10021023	Surface resistivity, IEC60093	: * / 1E10 Ω
Product Name	: TEKSOPREVENT	CTI, solution A, IEC60112	: 600
		Mechanical properties	
Model Number	: TEK1000	Tensile modulus, ISO527-2	: 3500/1500 MPa
		Yield stress, ISO527-2,	: 75/45 MPa
Date	: 03-28-2016	Yield strain, ISO527-2,	: 4/20 %
		Strain at break, ISO527-2	: 6/250 %
Technical specification		Charpy V-notch impact strength,-ISO179/1el	J : 80/N kJ/m2
Melting temperature,	: 1001 °C	Technical specification of Ball Enclosure	
ISO3146 Density, ISO1183	: 1.16 g/cm3	Durometer Range A	: 25 -85
Melt volume rate MVR 275/5,	: 140 cm3/10 min.	Tensile, Max. psi (Mpa)	: 1300 lbF (10.5kN)
ISO1133 Molding shrinkage, Test	: 0.8%	Elongation, max %	: 800
box 1.5mm Moisture absorption,		Specific Gravity	: 1.1
equilibrium-23°C/50% r.h. ISO62	: 2.6 – 3.2%	Continuous Temp Max	:800 °C
Thermal properties		Compression set	: Excellent
Deflection temperature 1.8MPa, ISO75-2	: 800 °C	Environmental and Immersion Properties	
Deflection temperature 0.45 MPa, ISO75-2	: 1600 °C	Electrical Resistivity	: Excellent*
RTI electrical (thickness 1.5mm), UL746B	: 1050 °C	Flame Resistance	: Good*
<u>Flammability</u>		Impact resistance	: Good*
UL94 rating	: V-0 (>=0.4)	Tear Resistance	: Fair
Hot wire ignition, ASTM D 3874-	: 2 (>=1.5)	Continuous Temp Max	: 1472 °F
88 High current arc ignition,	: 0 (>=0.4)	Intermittent Temp Max	: 1122 °F
UL746A,Fire/ignition performance-		Weather change tolerance	: Excellent*
(UL94+HAI+HWI), UL746C	: 1.5 mm	Oxidation Resistance	: Excellent*
GWFI, IEC60695-2-12	: 1400 °F	Ozone Resistance	: C
GWIT, IEC60695-2-13	: 1350 °F	300°F Steam Resist.	: Good*
Limiting Oxygen index LOI ISO4589-2	: > 35 %	Temperature and Environment stress -	
Spec. optical density of smoke Ds,-		Screening tests	: Good*
25kW/m2, EN ISO5659-2	: 60	Salt water dipping test	: Good*
Conventional index of toxicity		UV test	: Good*
CIT, - 25kW/m2, EN ISO5659-2	:1	Vibration Endurance test	: Excellent*
Electrical properties		Impulse Current Test (40KA-240KA)	: Good*
Dielectric constant at 1MHz, IEC60250	: 3.6/6	(Equipment are tested only on one pi	ece in a lot of 100 pieces*)
Dissipation factor at 1MHz, IEC60250	: 200/3000		

Quality Check Result: PASSED

Stamp & Signature

Kent

Head, Quality Control



भारत सरकार Government of India राष्ट्रीय परीक्षण शाला (द.क्षे.) NATIONAL TEST HOUSE (SR)

347218

तरमणी, चेन्नई - 600 113. Taramani, Chennai - 600 113. Phone : 22432374, 22431157 Fax : 22433158 email : nthsr@tn.nic.in परीक्षण प्रमाण पत्र

TEST CERTIFICATE

INTERIM/FINAL REPORT

पर्भाण प्रमाण पन सं Test Certificate No. NTH(SR)/EL(C)/2014/00176A जारी होने की तिथि Date of Issue 23/04/2014

कोड नं Code No. 1396938243840

पुष्ठ Page

पृष्ठीं की संख्वा No of Pages

जिसे जारी करना है

Issued To

TEKSAI POWER SECURE SOLUTION PVT.LTD.

पता

Address

3/860.BLUE STAR INDUSTRIES COMPOUND.

PUDUSSERY, KANJIKODE, PALLAKKAD, KERALA-678623

ग्राहक का सन्दर्भ सं एवं दिनांक

Customer's Ref. No.

TPSS/2014

Date: 25/01/2014

पंजिका सं एवं दिनांक

Register No & Date

00176/NTH(SR)/EL(C)/08/04/2014

परीक्षण सामग्री का विवरण

Description of Test Item

परीक्षण सामग्री का पहचान Identification of Test Item Earthing material

Printing marking on the bag: "Teksai-Ultra"

नमना का विशिष्टि (यदि ही)

Product Specification (Flany)

Electrical Resistivity test as per customer's specification

नमना प्राप्ति की तिथि

Date of Receipt of the Test Item

08/04/2014

कार्य सम्पादन की तिथि

Date(s) of Performance of Tests

व्यावद्वत प्रणाली का पहचान Method(s) used for Test

नम्ना प्रकिया जहाँ प्रासंगिक हों Sampling Procedure where relevant From: 08/04/2014

23/04/2014

Electrical Resistivity test as per customer's specification

NA

Tested By

N. Zorihl Kelen St Natarajan Joseph kalaiselvan

SO Flectrical

Checked By

SO Flectrica

S.B. Nanda Kumar

Scientist-SC(Electrical)





PHARMACEUTICALS LIMITED (ANALYTICAL DIVISION)
ISO 9001 : 2008 Certified
Govt. Approved Test House

4/9, Kirti Nagar Industrial Area, New Delhi-110 015 Tele: 011-45754575 Fax: 011-45754545 e-mail: arbrolab@arbropharma.com, Website: www.arbropharmaindia.com CERTIFICATE OF ANALYSIS

ISO 9001 - 2008

: EARTHING BACKFILL COMPOUND Sample

:N.S.

Report No. :NR-11060906

P

Received On :09/06/2011

Mfg.Lic.No. : N.S.

Ref. No.

:N.S.

Submitted By : GENIUS PROTECTION SYSTEM. (P) LTD.

:248A, RATI COMPLEX, RAMA MKT., MUNIRKA, N DELHI.

Batch Size

Sample Qty

N.S.

Address Batch No.

Mfg. Date N.S.

Expiry Date

N.S.

100GM.

N.S.

RESULTS OF ANALYSIS

Date of start of analysis 10-06-11 Date of Completion of analysis 13-06-11.

Description

Supplied By

:- Black powder.

<\$1.No.> <Parameters> <Results> <Limit (MAX)> B - TOXIC METALS

:- 0.251ppm 1000.0ppm 1. Mercury(as Hg) 2. Lead(as Pb) :- 8.225ppm 1000.0ppm

Cadmium (as Cd) :- 0.128ppm 100.0ppm 3.

1000.0ppm Hexa-Chromium (as Cr): - Less than 1.0ppm

Remark :- Observed value for Pb, Cd, Hg & Cr+6 are very low from the max limit, Hence sample complies the ROHS.

REMARKS : PARTY ASKED FOR THE ABOVE TESTS ONLY

Page

1 of 1

Person In Charge

Date : Monday, June 13, 2011



CENTRAL POWER RESEARCH INSTITUTE

(Member of STL)

Sheet 1 of 4

TEST REPORT

Test Report Number

SC11376A

Dated: 29th August, 2011

Name & Address of the Customer

M/s. Teksal Power Secure Solution Pvt. Ltd... 3/860. Blue Star Industrial Compound, Pudussery,

Kanjikodu, Palaghat, Kerala - 678 029.

Name & Address of the Manufacturer

M/s. Teksai Power Secure Solution Pvt. Ltd., 3/860, Blue Star Industrial Compound, Pudussery, Kanjikodu, Palaghat, Kerala - 678 029.

Particulars of sample tested Condition of the sample on Receipt

GI Earthing Electrode

New.

Type Designation Serial Number(s) Number of samples tested Date (s) of test (s)

Teksal One

10th August, 2011 CPRI sample code no(s). SC11S1323

Particulars of tests conducted

Short-Time current Test in accordance with Standard / specification Customer's instruction

Sampling plan Customer's requirement Deviations if any

Not applicable 20 kA rms for 1.0 s.

Name of the witnessing persons

Customer's representative Other than customer's representative

Mr. Praveen P.V. Mr. Jacob George

Test subcontracted with address of the laboratory

None.

Documents constituting this report (in words)

Number of sheets Four Number of oscillograms One Number of graphs MIL Number of photos Two Number of test circuit diagrams One Number of drawings One

(N. Maheswara Rao) **Test Engineer**



Swarai Kumar Das) Joint Director

AUTHORISED SIGNATORIES






Made in France, EU

ALTERNATE CURRENT

LSGBC50



APPLICATIONS



Dimensions

- B+C class Surge Protective Device for AC Power System.
- Sensitive electronic equipment
- Telecom centers
- Automatic control centers
- Intelligent buildings
- Industrial enterprises
- Medical institutes

FEATURES:

- ●DIN rail mounting for easy installation
- Plug connectors for quick and easy connection or rewiring
- 50kA lightning impulse current Iimp
- Thermal disconnect device
- Status indicators visually verify protection level

TECHNICAL PARAMETER:

Model	LSGBC50
Electrical Parameter	
Nominal working voltage Un	50/60Hz 220/380V,
Max. continuous operating voltage Uc	385V
Nominal discharge current (8/20µs) In	50kA
Lightning impulse current(10/350µs) Iimp	15kA
Protection level @20kA, 8/20µs Up	2000V
Response time tA	100ns
Protection model	L1/L2/L3-N,N-PE
Mechanical characteristics	
Dimension	90 (H)×144 (W)×68(L)mm
Weight per unit	1200g
Mounting	35mm DIN rail
Connecting diameter	\geqslant 10mm^2
IP code	IP20
Working conditions	Temperature: -40 to 80° C,
	Relative humidity: ≤95%
Approval	FCC, CE, ROHS



PHOENIX CONTACT GERMANY

CTRL 1.5 Surge Arrester - Flashtrab FLT 35 CTRL 1.5



Features:-

- Lighting current arrester with encapsulated N-PE spark gap and ignition electronics
- 2 Channel Protection level 1.5 KV
- Housing width 40 mm (3 Div)

Specification:-


Un 230 V

Uc 440 V, 260 V

Up ≤1.5 kV

Imp 100 kA

T*C -40...+85



Confirmation on quality assurance according to nuclear standard KTA 1401

On behalf of the German nuclear power plant operators, **E.ON Kernkraft GmbH** as a partner of the VGB PowerTech e.V. working group Assessment of Contractors confirms



Phoenix Contact Group

valid for the sites

Phoenix Contact GmbH & Co. KG
Flachsmarktstraße 8, D-32825 Blomberg
Phoenix Contact Electronics GmbH
Dringenauer Straße 30, D-31812 Bad Pyrmont
Phoenix Contact Deutschland GmbH
Flachsmarktstraße 8, D-32825 Blomberg
Phoenix Contact Power Supplies GmbH
Oberes Feld 1, 33106 Paderborn

and the scope of supply and services

Design, manufacturing and sale of electrical and electronic connecting elements, power supply and surge voltage protection modules, as well as electronic interface systems

the qualification for system- and product related quality assurance.

The assessment was performed on April 20th and 21st, 2016 by

EUROCERT®

Gesellschaft zur Qualifizierung von Unternehmen mbH

based on the standard **KTA 1401** as well as on the assessment documents of the VGB PowerTech e.V. working group Assessment of Contractors in consideration of product related requirements.

Details of the assessment are given in the report Eurocert 2016/02.

This confirmation is valid until **March 08th, 2019** provided that the conditions on which the assessment was based have not been changed.

Hanover, April 29th, 2016

i.V. Blisraudel

EnBW





Vattenfall Europe Nuclear Energy



E.ON Kernkraft GmbH



Deutsche Akkreditierungsstelle GmbH

Entrusted according to Section 8 subsection 1 AkkStelleG in connection with Section 1 subsection 1 AkkStelleGBV

Signatory to the Multilateral Agreements of EA, ILAC and IAF for Mutual Recognition

Accreditation



The Deutsche Akkreditierungsstelle GmbH attests that the calibration laboratory

Phoenix Contact GmbH & Co. KG Flachsmarkstraße 8, 32825 Blomberg

is competent under the terms of DIN EN ISO/IEC 17025:2005 to carry out calibrations in the following fields:

Dimensional quantities

Length

- Length measuring instruments
- Diameter
- Thread

Electrical quantities

DC and low frequency quantities

- Voltage
 - DC voltage
 - AC voltage
- Current
 - DC current
 - AC current
- DC resistance

Time and frequency

- Frequency
- Time interval

The accreditation certificate shall only apply in connection with the notice of accreditation of 24.01.2018 with the accreditation number D-K-12161-01 and is valid until 23.02.2020. It comprises the cover sheet, the reverse side of the cover sheet and the following annex with a total of 7 pages.

Registration number of the certificate: D-K -12161-01-00

Braunschweig, 24.01.2018

Dr. Heike Manke Head of Division Translation issued: 03.04.2018

Head of Division

This document is a translation. The definitive version is the original German accreditation certificate.





CERTIFICATE

awarded to

Phoenix Contact GmbH & Co.KG Flachsmarktstr. 8 32825, Blomberg Germany

DQS GmbH

confirms, as an IRIS Certification™ approved certification body, that the Management System of the above organization has been assessed and found to be in accordance with the

IRIS Certification™ rules:2017 and based on ISO/TS 22163:2017

for the activities of Design and Development and Manufacturing for the scopes of certification: 12 (Electrical wiring), 19 (Single railway components)

electromechanical and electrical connecting elements, plug connectors, surge voltage protection, cable assembly, tools and components for electrical engineering

Certificate valid from: 04/03/2018 Certificate valid until: 03/03/2021*

Current date: 06/03/2018

Certificate-Register-No: 239330

on Hereh

Certification body address: August-Schanz-Straße 21, 60433 Frankfurt am Main, Germany

^{*} Providing that the subsequent surveillance audits are successful before the validity date of the previous audit.





Enclosure 1 of Certificate No.: 239330

Phoenix Contact GmbH & Co.KG Flachsmarktstr. 8 32825, Blomberg Germany

The location is supported by the following remote locations:

Address	Scope/Process
Phoenix Contact GmbH & Co. KG Bahnhofstr. 9 32816 Schieder-Schwalenberg, Germany	Logistics, Professional Education

Current date: 06/03/2018

Certificate-Register-No: 239330

la Hereh

^{*} Providing that the subsequent surveillance audits are successful before the validity date of the previous audit.